


**SCADA/MMP SITE MATERIALS**

- CABINET = Hoffman A60H3612ALLP/SPL w/Back Plane  
*(Special Order HRSD# 583JG for 60x36x18)*
- DATA LOGGER = Telog 3307A or 3314 w/Modem & Antenna
- FLOW METER = Fuji #FLVS1213 (24VDC)
- BATTERY CHARGER = Newmar #PT-24-20U (24VDC)
- BATTERIES (X4) = 100Ah Gel Cell Batteries (12VDC)
- CABINET LIGHT = Various (120VAC)
- PANDUIT = Various
- DIN RAIL = Various
- TERMINAL STRIPS = Weidmuller # WDU2.5 1020000000 (Beige)  
Weidmuller # WDU2.5 1020090000 (Green)  
Weidmuller # (Black) ?  
Weidmuller # (Red) ?
- OUTLET = Weidmuller #RS-Simplex 9915480000 (120VAC)
- CIRCUIT BREAKER = Square D #QOU120 (20A DIN Rail Mount)
- POST = Various 4 X 6 X 8
- ANTENNA MAST 20' = Various
- MISC WIRING = Various
- RTU = MOSCAD Ace (Optional)
- POWER SUPPLY = IDEC 24 VDC # PS5R-SD24 (Optional)
- POWER SUPPLY = IDEC 14 VDC # PS5R-SD12 (Optional)



<b>HRSD</b> <small>Hydrologic Research Services, Inc. for a Diverse World</small>				
DESCRIPTION				
<b>SCADA/MMP SITE</b>				
DRAWING DESCRIPTION				PAGE
REV.	A	DATE	11-21-2011	BY: L. Imman
REV.	B	DATE	11-22-2011	BY: L. Imman
REV.	C	DATE	10-21-2010	BY: L. Imman
				1