

HRSD SWIFT Research Center (SWIFTRC) Quarterly Report on SWIFT Water Quality Targets

This report documents SWIFT Water Quality results for recharge operations from October 1 - December 31, 2019. The compliance requirements are documented in HRSD's SWIFT Underground Injection Control Inventory Information Package (UIC-IIP) submitted to EPA Region III in January 2018. These requirements are noted in the following tables (Tables 1-4), extracted from Attachment B of the UIC-IIP. Figures 1 and 2 and Table 6 provide a summary of the data from the referenced quarter of operations relative to these SWIFT Water Quality Targets. Table 6 represents a summary of all analytes that were present above the laboratory reporting limit. A detailed table identifying the full suite of parameters monitored for the purpose of evaluating compliance with the SWIFT Water Quality Targets can be found as an Appendix to this report.

| Parameter | Proposed Regulatory Limit | Non-Regulatory Action/Goal |
|--|---|---|
| EPA Drinking Water Primary Maximum Contaminant Levels (MCLs) | Meet all primary MCLs | N/A |
| Total Nitrogen | 5 mg/L Monthly Average; 8 mg/L Max Daily | Secondary Effluent Critical Control Point (CCP) Action Limit for Total Inorganic Nitrogen (TIN) = 5 mg/L-N; CCP Action Limit for SWIFT Water Total Nitrogen (TN) = 5 mg/L-N |
| Turbidity | Individual Filter Effluent (IFE) < 0.15 NTU 95% of time and never >0.3 NTU in two consecutive 15 min measurements | CCP Action Limit IFE of 0.10 NTU to initiate backwash or place a filter in standby |
| Total Organic Carbon (TOC) ¹ | 4 mg/L Monthly Average 6 mg/L Maximum | Critical Operating Point (COP) Action Limit to Initiate GAC Regeneration |
| Total Coliform | <2 CFU/100 mL 95% of time; Not to exceed geometric mean of 3 CFU/100 mL, based on a running calculation of 20 days of daily samples for total coliforms | N/A |
| E.coli | Non-detect | N/A |
| TDS ² | N/A | Monitor PAS Compatibility |

Table 1: SWIFTRC Regulatory and Monitoring Limits for SWIFT Water

¹ Regulatory limit applies to the TOC laboratory analysis which is collected at a frequency of 3 times per week.

² No limit for TDS proposed as the primary driver is aquifer compatibility. The concentration of SWIFT Water at the SWIFTRC generally ranges from 500-850 mg/L.




Figure 1: Percentile distribution of 15-minute average Individual Filter Effluent (IFE) Turbidities for Biofilters 1-4 (IFE1-4) and Combined Filter Effluent (CFE). There were no 15-minute periods in this quarter with biofilter effluent turbidity values greater than 0.3 NTU. The 95% measured value for each biofilter IFE and the CFE was less than 0.15 NTU for each month in this quarter.




Figure 2: Distribution of Monthly SWIFT Water pH values.

Monitoring at the SWIFTRC also includes monitoring for performance indicators as documented in Table 2, extracted from Attachment B of the UIC-IIP.

| Constituent | Category | Trigger Value | Unit | Notes |
|-------------------|-------------------------|---------------|------------|---|
| 1,4-Dioxane | Public Health | 1 | µg/L | CCL4; CA Notification Limit |
| 17-β-Estradiol | Public Health | TBD | ng/L range | CCL4 |
| DEET | Public Health | 200 | µg/L | MN Health Guidance Value |
| Ethinyl Estradiol | Public Health | TBD | ng/L range | CCL4 |
| NDMA | Public Health | 10 | ng/L | CCL4; CA Notification Limit |
| Perchlorate | Public Health | 6 | µg/L | CA Notification Limit |
| PFOA+PFOS | Public Health | 70 | ng/L | CCL4; EPA Health Advisory |
| TCEP | Public Health | 5 | µg/L | MN Health Guidance Value |
| Cotinine | Treatment Effectiveness | 1 | µg/L | Surrogate for low molecular weight, partially charged cyclics |
| Primidone | Treatment Effectiveness | 10 | µg/L | |
| Phenytoin | Treatment Effectiveness | 2 | µg/L | |
| Meprobamate | Treatment Effectiveness | 200 | µg/L | High occurrence in wastewater treatment plant effluent |
| Atenolol | Treatment Effectiveness | 4 | µg/L | |
| Carbamazepine | Treatment Effectiveness | 10 | µg/L | Unique structure |
| Estrone | Treatment Effectiveness | 320 | ng/L | Surrogate for steroids |
| Sucralose | Treatment Effectiveness | 150 | mg/L | Surrogate for water soluble, uncharged chemicals with moderate molecular weight |
| Triclosan | Treatment Effectiveness | 2,100 | µg/L | Chemical of interest |

TBD = to be determined

Table 2: SWIFTRC Non-Regulatory Performance Indicators

Pathogen Log Removal Value (LRV) is not strictly regulated but the SWIFTRC has been designed and is operated to achieve at least 12 LRV for viruses and 10 LRV for *Cryptosporidium* and *Giardia* through a combination of advanced treatment processes and soil aquifer treatment. Table 3 provides a treatment process pathogen LRV summary for recharge conditions. Table 4 provides additional monitoring that is being completed to document compliance with the LRVs for ozone and UV.

| Parameter | Floc/Sed (+BAC) | Ozone | BAC+GAC | UV | Cl2 | SAT | Total |
|------------------------|-----------------|-------------|---------|----|-----|-----|---------|
| Enteric Viruses | 2 | 0-3 (TBD) | 0 | 4 | 0-4 | 6 | 12-19 |
| <i>Cryptosporidium</i> | 4 | 0 | 0 | 6 | 0 | 6 | 16 |
| <i>Giardia</i> | 2.5 | 0-1.5 (TBD) | 0 | 6 | 0 | 6 | 14.5-16 |

Table 3: SWIFTRC Pathogen LRV for Potomac Aquifer System (PAS) Recharge.

| |
|---|
| Ozone LRV |
| Ozone Influent Temperature |
| Ozone Influent Flow |
| Liquid Phase Ozone Concentration ¹ |
| Contact Time |
| CT |
| UV LRV |
| UV Intensity, each reactor |
| UVT, GAC Combined Effluent |
| Reactor Flow, each |
| Calculated Dose, each Lamp |
| Status, each |

¹ The ozone liquid phase probe is verified with lab grab samples performed at least once per week.

Table 4: Additional Monitoring to Support Ozone and UV LRV. All data are collected as continuous measurements. The 15-minute LRV data is submitted in Table 6.

Critical Control Points

The SWIFTRC incorporates Critical Control Points (CCP) throughout the treatment process, per Attachment G of UIC-IIP to verify that treatment goals are being met at each of the individual processes. A violation of any CCP means that the SWIFTRC may not be producing water that meets the treatment goals and will trigger a diversion of the SWIFT Water so that it is not directed to the recharge well. In most instances, the SWIFTRC will continue to operate through the CCP violation, but the SWIFT Water will be diverted back to the Nansmond Plant chlorine contact tanks (CCT).

CCPs have alert values at which point the operator is expected to take action to correct the performance as well as the alarm values at which point an automated response will trigger action and prevent flow from going to the recharge well. Both

the alert and alarm values will be measured consistently for a specified duration before action is taken so that blips in online analyzers do not trigger action. The specific values for the alert and alarm levels will be configured as adjustable set points in the Distributed Control System (DCS) and optimized as needed to meet the water quality requirements.

Table 5 shows the current CCPs in effect at the SWIFTRC. Modifications have been made to the CCPs since startup as compared to the original design documents in order to optimize their performance. Each of the modifications from previous quarters was discussed in each of the previous reports. Additional modifications made during this period of operation are noted in the table in redline and discussed below.

- Decreased the Influent Pump Station Conductivity CCP alert value from 1,500 $\mu\text{S}/\text{cm}$ to 1,400 and alarm value from 1,800 $\mu\text{S}/\text{cm}$ to 1,600. Conductivity is used as a surrogate for bromide, however this correlation is affected by high tides. Data collected during high conductivity events due to high tides at Nansmond Plant indicated that 1,600 $\mu\text{S}/\text{cm}$ is the appropriate alarm value.

| Parameter | Alert Value | Alarm Value | Unit | Action |
|--|------------------------|------------------------|-----------------------------|---|
| Critical Control Points (CCPs) | | | | |
| Influent Pump Station Conductivity | 1,500 1,400 | 1,800 1,600 | microSiemens per centimeter | Place Biofilters in Filter To Waste |
| Influent Pump Station Total Inorganic Nitrogen | 4.0 | 5.0 | mg/L-N | Place Biofilters in Filter To Waste |
| Influent Pump Station Turbidity | 3.5 | 5.0 | NTU | Place Biofilters in Filter To Waste |
| Preformed Chloramine Failure on Injection | N/A | Failure | mg/L | Divert SWIFT Water |
| Total Chlorine Post Injection upstream of ozone | 2.0 | 1.0 | mg/L | Divert SWIFT Water |
| Chloramine injection upstream of ozone | 2.0 | 1.0 | mg/L | Divert SWIFT Water |
| Ozone Feed | N/A | Failure | N/A | Open Biofilter Backwash Waste Valve |
| Ozone Contactor Calculated LRV – Virus | <120% LRV Goal | <110% LRV Goal | % | Open Biofilter Backwash Waste Valve |
| Biofilter Individual Effluent Turbidity | 0.1 | 0.15 | NTU | Place That Biofilter in Filter To Waste |
| Biofilter Combined Filter Effluent Turbidity | 0.1 | 0.15 | NTU | Place Biofilters in Filter To Waste |
| GAC Combined Effluent TOC, instantaneous online analyzer | 4.0 | 5.0 | mg/L | Divert SWIFT Water |
| UV Reactor Dose | <120% of Dose Setpoint | <105% of Dose Setpoint | % | Divert SWIFT Water |
| Free Chlorine CT (<i>This CCP is not being used since free chlorination of the SWIFT Water is not currently being practiced</i>) | <120% of CT Target | <105% of CT Target | % | Divert SWIFT Water |

| Parameter | Alert Value | Alarm Value | Unit | Action |
|---------------------------------|----------------------|----------------------|-------------|-------------------------------------|
| GAC Combined Effluent Nitrite | 0.25 | 0.50 | mg/L-N | Divert SWIFT Water |
| SWIFT Water TN | 4.5 | 5.0 | mg/L-N | Divert SWIFT Water |
| Ozone dose | 70 | 80 | lbs/day | Place Biofilters in Filter To Waste |
| Tasting System Free Chlorine CT | <110% of Required CT | <100% of Required CT | mg-min/L | Shut Down Tasting System |
| Tasting System Total Ammonia | 0.1 | 0.3 | mg/L-N | Shut Down Tasting System |

Table 5. Critical Control Points for the SWIFTRC

| Parameter | Units | Maximum Contaminant Level (MCL) or MCL Goal (MCLG) where numerical MCL not expressed. Values noted for indicator compounds are non-regulatory screening values | Minimum Report Level ¹ | Required Monitoring Frequency | October | | | November | | | December | | |
|---|------------|--|-----------------------------------|-------------------------------|----------------------|---------|------------------|----------------------|---------|------------------|----------------------|---------|------------------|
| | | | | | Average ² | Maximum | Numer of Samples | Average ² | Maximum | Numer of Samples | Average ² | Maximum | Numer of Samples |
| Regulatory Parameters | | | | | | | | | | | | | |
| Total Nitrogen (TN) | mg/L | NA | 0.50 | Daily ³ | 3.33 | 3.78 | 25 | 3.29 | 3.86 | 23 | 3.53 | 4.20 | 23 |
| NO ₃ | mg/L | 10 | 0.01 | Daily ³ | 2.58 | 3.12 | 25 | 2.59 | 3.16 | 23 | 2.72 | 3.41 | 23 |
| NO ₂ | mg/L | 1 | 0.01 | Daily ³ | 0.03 | 0.11 | 25 | 0.02 | 0.12 | 23 | 0.01 | 0.06 | 23 |
| Turbidity | NTU | NA | 0.01 | Continuous | Figure 1 | | | | | | | | |
| Total Organic Carbon (TOC) | mg/L | NA | 1.00 | 3x/Wk ³ | 2.82 | 3.12 | 11 | 3.02 | 3.20 | 9 | 3.61 | 3.86 | 9 |
| pH | | NA | NA | Continuous | Figure 2 | | | | | | | | |
| TDS ⁴ | mg/L | Potomac Aquifer System Range: 694-8,720 | 2.5 | Monthly | | 840 | 1 | | 780 | 1 | | 705 | 1 |
| Microorganisms | | | | | | | | | | | | | |
| Total Coliform ⁵ | MPN/100 mL | MCLG = 0 | 1 | Daily ³ | <1 | <1 | 25 | <1 | <1 | 23 | 1 | 2 | 23 |
| E. coli | MPN/100 mL | NA | 1 | Weekly | <1 | <1 | 25 | <1 | <1 | 23 | <1 | <1 | 23 |
| Disinfection Byproducts | | | | | | | | | | | | | |
| Bromate | µg/L | 10 | 0.15 | Monthly | | 4.01 | 1 | | 4.19 | 1 | | 3.76 | 1 |
| HAAs | | | | | | | | | | | | | |
| Dichloroacetic acid | µg/L | | 0.60 | Monthly | | 1.27 | 1 | | 1.70 | 1 | | 1.75 | 1 |
| Trichloroacetic acid | µg/L | | 0.20 | Monthly | | 0.42 | 1 | | <0.2 | 1 | | 0.61 | 1 |
| Monochloroacetic acid | µg/L | | 0.60 | Monthly | | <0.6 | 1 | | <0.6 | 1 | | <0.6 | 1 |
| Bromoacetic acid | µg/L | | 0.40 | Monthly | | <0.4 | 1 | | <0.4 | 1 | | <0.4 | 1 |
| Dibromoacetic acid | µg/L | | 0.20 | Monthly | | 1.67 | 1 | | 0.34 | 1 | | 0.29 | 1 |
| Total Haloacetic Acids | µg/L | 60 | | | | | | | | | | | |
| Disinfectants | | | | | | | | | | | | | |
| Monochloramine (as Cl ₂) ⁶ | mg/L | 4 | | Continuous | 0.59 | 1.33 | | 0.41 | 1.07 | | 0.30 | 0.55 | |
| Chlorine (as Cl ₂) ⁶ | mg/L | 4 | | Continuous | 0.60 | 1.19 | | 0.40 | 0.56 | | 0.30 | 0.53 | |
| Inorganic Chemical | | | | | | | | | | | | | |
| Antimony | µg/L | 6 | 0.5 | Monthly | | <0.5 | 1 | | <0.5 | 1 | | 0.6 | 1 |
| Barium | mg/L | 2 | 0.005 | Monthly | | 0.013 | 1 | | 0.008 | 1 | | 0.007 | 1 |
| Cyanide (total) | µg/L | 200 | 10 | Monthly | | <10 | 1 | | <10 | 1 | | 23 | 1 |
| Fluoride | mg/L | 4.0 | 0.05 | Monthly | 1.05 | 1.94 | 25 | 0.95 | 1.04 | 22 | 0.88 | 0.94 | 24 |
| Organic Chemicals | | | | | | | | | | | | | |
| Radionuclides | | | | | | | | | | | | | |
| Beta particles and photon emitters | pCi/L | 4 mrem/yr ⁷ | 3 | Monthly | | 18 | 1 | | 18 | 1 | | 18 | 1 |

| Parameter | Units | Maximum Contaminant Level (MCL) or MCL Goal (MCLG) where numerical MCL not expressed. Values noted for indicator compounds are non-regulatory screening values | Minimum Report Level ¹ | Required Monitoring Frequency | October | | | November | | | December | | |
|---|--------------------|--|-----------------------------------|-------------------------------|----------------------|---------|------------------|----------------------|---------|------------------|----------------------|---------|------------------|
| | | | | | Average ² | Maximum | Numer of Samples | Average ² | Maximum | Numer of Samples | Average ² | Maximum | Numer of Samples |
| Non-regulatory Performance Indicators | | | | | | | | | | | | | |
| Public Health Indicators | | Trigger Limits | | | | | | | | | | | |
| 1,4-dioxane | µg/L | 1 | 0.06 | Quarterly | 0.55 | 0.58 | 2 | 0.52 | 0.56 | 4 | 0.54 | 0.62 | 4 |
| Perchlorate | µg/L | 6 | 0.50 | Quarterly | | 0.70 | 1 | | | | | | |
| Treatment Efficacy Indicators | | Trigger Limits | | | | | | | | | | | |
| Sucralose | ng/L | 150,000,000 | 100 | Quarterly | | 780 | 1 | | | | | | |
| Additional Monitoring (Ozone & UV LRV) | | | | | | | | | | | | | |
| Ozone Virus LRV | | | | Continuous | 4.50 | 3.36 | | 4.57 | 3.61 | | 4.51 | 3.94 | |
| Ozone Giardia LRV | | | | Continuous | 2.13 | 1.57 | | 2.31 | 1.83 | | 2.27 | 1.98 | |
| UV Dose Reactor 1 | mJ/cm ² | | | Continuous | >186 | >186 | | >186 | >186 | | >186 | >186 | |
| UV Virus LRV Reactor 1 | | | | Continuous | >4 | >4 | | >4 | >4 | | >4 | >4 | |
| UV Dose Reactor 2 | mJ/cm ² | | | Continuous | >186 | >186 | | >186 | >186 | | >186 | >186 | |
| UV Virus LRV Reactor 2 | | | | Continuous | >4 | >4 | | >4 | >4 | | >4 | >4 | |

¹ When minimum reporting limits varied during the quarter, the highest minimum reporting limit used is identified.

² Analytical results less than the reporting limit were treated as zero for the purposes of the averaging calculation.

³ Daily samples are typically not collected on days in which there is no or limited recharge. TOC sample collection occurs routinely on Monday, Wednesday and Friday when recharging. Limited or inconsistent recharge impacts the collection of daily samples, particularly for the microbiological samples collected for total coliform and e coli which have limited holding time requirements. Recharge occurred on 26 days in October, 25 days in November, and 29 days in December. Recharge was limited for an additional 1 day in October, 2 days in November and 6 days in December.

⁴ TDS of the Potomac Aquifer System is based on the averages within the upper, middle and lower Potomac Aquifer as determined during baseline monitoring.

⁵ A positive Total coliform result was documented on December 5 with a result of 1 CFU/100 mL and again on December 31 with a result of 2 CFU/100 mL. In both samples E. coli were absent.

⁶ The maximum residual disinfectant level (or MRDL) MCL for monochloramine and chlorine are based on annual averages.

⁷ The measurement unit for beta particles and photon emitters is pCi/L while the MCL is expressed as mrem/yr. Per EPA's Implementation Guidance for Radionuclides (EPA 816-F-00-002, March 2002), the screening threshold for beta particles and photon emitters is 50 pCi/L. If sample concentrations exceed 50 pCi/L, each individual beta particle and photon emitter is converted from pCi/L to mrem using the EPA designated conversion tables, currently available in the referenced document.

Recharge Statistics

The total volume recharged during this operational period was 50.5 million gallons. 4.8 million gallons was backflushed for a net recharge of 45.7 million gallons (Figure 3). Brief backflushing periods occur as part of routine well maintenance on an approximate daily basis.




Figure 3: Recharge and Backflush Volumes, October 1 – December 31, 2019.

Conventional Monitoring Wells

The conventional monitoring well for the upper zone of the Potomac Aquifer (MW-UPA), located approximately 400 ft from the recharge well, has been monitored daily for fluoride to evaluate the migration of recharge water. Fluoride concentration in SWIFT Water averaged 0.96 mg/L in the May – December 2019 operational period. Monthly average fluoride concentration in MW-UPA averaged 4.44 mg/L during this same operational period. Despite the lack of fluoride response in MW-UPA, a review of total organic carbon (TOC) concentration in MW-UPA indicated the potential arrival of the recharge front (Figure 4) with TOC concentrations appearing to begin to stabilize in October. Similar increases in TOC have not been observed in the monitoring wells located in the middle and lower zones of the Potomac Aquifer (MW-MPA, MW-LPA). Based on the observed increase in TOC in MW-UPA, samples for all PMCLs and the indicator compounds were collected in November. All parameters were less than the PMCL and all regulated organics were non-detect. Nitrite and arsenic observations are described in further detail in the sections below.

Monitoring identified quantifiable concentrations of the indicator compounds, 1,4 dioxane, NDMA, and sucralose (Table 7). All reported values were less than the action thresholds (“trigger values”) identified in Table 2 of this report.

NDMA is most commonly < 2.00 ng/L in SWIFT Water. With reported MW-UPA sample concentrations of NDMA as high as 4.45 ng/L, HRSD is working to better understand NDMA formation potential within the aquifer. Studies are on-going and will be reported upon in an upcoming quarterly report.




Figure 4: TOC concentration in the Upper Potomac conventional monitoring well, MW-UPA. TOC concentration in the October – December monitoring period in MW-UPA averaged 1.4 mg/L. The monthly average of SWIFT Water TOC since the start of operations is 2.1 mg/L. The monthly average for the 2018 and 2019 operational periods was 1.5 and 2.6 mg/L, respectively.

Table 7: Indicator compounds quantified in MW-UPA. Average values are not calculated when the maximum value reported represents a single sample.

| Indicator | Indicator Trigger Limit | MW-UPA | | | | SWIFT Water | |
|-------------------|-------------------------|----------|-----|----------|------|----------------------|-------------|
| | | November | | December | | 2018-2019 Operations | |
| | | Max | Avg | Max | Avg | Max | Monthly Avg |
| 1,4 Dioxane, µg/L | 1 | 0.38 | - | 0.39 | 0.38 | 0.61 | 0.40 |
| NDMA, ng/L | 10 | 4.45 | - | 4.15 | 2.80 | 5.43 | 1.15 |
| Sucralose, ng/L | 150,000,000 | 340 | - | 300 | - | 780 | 175 |

As additional data are generated, we will be able to evaluate the capacity for additional soil aquifer treatment over multiple months of travel time. Annual monitoring for PMCLs

and indicator compounds is also occurring in wells located in the upper and middle Potomac at USGS's Nansmond Research Station, located approximately 1,000 ft from the recharge well. This is expected to provide further insights into travel time and the changing characteristics of the recharge front as it moves through the aquifer.

Due to the shut-down of the SWIFT Research Center for warranty repairs, it is difficult to quantify a travel time associated with this movement of recharge water to MW-UPA. At the beginning of October when TOC concentration appears to begin to stabilize, the net volume of recharge water was approximately 148 million gallons. A bromide tracer study designed to resolve some of the existing uncertainty associated with travel time estimations will begin at the end of March.

Nitrite in MW-SAT Update

HRSD continues to monitor nitrite levels within the monitoring well located 50 ft from the recharge well, MW-SAT, and the conventional wells to better understand the occurrence of in situ partial denitrification and the potential for nitrite migration with the recharge front. Nitrite has consistently remained less than ½ the MCL in MW-SAT with a maximum nitrite concentration of 0.44 mg/L quantified in screen interval 9 in November. As described above, recharge water is being detected in the upper zone of the Potomac in the conventional monitoring well, MW-UPA. Nitrite concentrations in MW-UPA during this monitoring period remain <0.01 mg/L.

Arsenic in MW-SAT Update

As described in a brief report issued on May 16, 2019, the concentration of arsenic in MW-SAT screen interval 9 increased above the MCL of 10 µg/L in a sample collected on May 6, eight days after resuming recharge. Since that time, groundwater monitoring and soil column studies have been on-going to better understand the potential for arsenic mobilization within the aquifer. The concentration of arsenic in MW-SAT has remained < 3 µg/L since November and all monthly averages for the three-month monitoring period were < 2 µg/L (Table 8).

In October, the concentration of a single sample in interval 10 was 6.38 µg/L. Analytical results for the remaining three samples collected from interval 10 that same month were < 1.00, <1.00 and 1.01 µg/L, yielding a monthly average of 1.85 µg/L.

As described above, recharge water is being detected in the upper zone of the Potomac in the conventional monitoring well, MW-UPA. The concentration of arsenic in MW-UPA during this monitoring period remained <1.00 µg/L.

Table 8: Total arsenic concentration in selected screen intervals of MW-SAT. Total arsenic concentration in the remaining screen intervals was < 1.50 µg/L in each month of the monitoring period. Total arsenic concentration in the conventional monitoring wells, MW-UPA, MW-MPA and MW-LPA as well as SWIFT Water remained <1.00 µg/L during the monitoring period.

| MW-Sat Screen | Total Arsenic, µg/L | | | | | |
|------------------|---------------------|------|----------|------|----------|------|
| | October | | November | | December | |
| | Max | Avg | Max | Avg | Max | Avg |
| 2 | 3.72 | 1.76 | 2.02 | 1.64 | 2.24 | 1.23 |
| 3 | 1.59 | 1.37 | 1.74 | 1.51 | 1.56 | 1.39 |
| 5 | 1.87 | 1.81 | 2.14 | 1.79 | 1.75 | 1.62 |
| 6 | 1.80 | 1.06 | 1.16 | 1.14 | 1.21 | 1.10 |
| 9 | 1.43 | 0.91 | 1.97 | 1.60 | 2.60 | 1.99 |
| 10 | 6.38 | 1.85 | 1.59 | 0.97 | 1.10 | 0.42 |

Appendix
Monitoring Data for SWIFT Water Quality Regulatory Targets

| Parameter | Units | Maximum Contaminant Level (MCL) or MCL Goal (MCLG) where numerical MCL not expressed. Values noted for indicator compounds are non-regulatory screening values | Minimum Report Level ¹ | Required Monitoring Frequency | October | | | November | | | December | | |
|--------------------------------|------------|--|-----------------------------------|-------------------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|
| | | | | | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples |
| Regulatory Parameters | | | | | | | | | | | | | |
| Total Nitrogen (TN) | mg/L | NA | 0.50 | Daily ³ | 3.33 | 3.78 | 25 | 3.29 | 3.86 | 23 | 3.53 | 4.20 | 23 |
| NO ₃ | mg/L | 10 | 0.01 | Daily ³ | 2.58 | 3.12 | 25 | 2.59 | 3.16 | 23 | 2.72 | 3.41 | 23 |
| NO ₂ | mg/L | 1 | 0.01 | Daily ³ | 0.03 | 0.11 | 25 | 0.02 | 0.12 | 23 | 0.01 | 0.06 | 23 |
| Turbidity | NTU | NA | 0.01 | Continuous | Figure 1 | | | | | | | | |
| Total Organic Carbon (TOC) | mg/L | NA | 1.00 | 3x/Wk ³ | 2.82 | 3.12 | 11 | 3.02 | 3.20 | 9 | 3.61 | 3.86 | 9 |
| pH | | NA | NA | Continuous | Figure 2 | | | | | | | | |
| TDS ⁴ | mg/L | Potomac Aquifer System Range: 694-8,720 | 2.5 | Monthly | | 840 | 1 | | 780 | 1 | | 705 | 1 |
| Microorganisms | | | | | | | | | | | | | |
| Total Coliform ⁵ | MPN/100 mL | MCLG = 0 | 1 | Daily ³ | <1 | <1 | 25 | <1 | <1 | 23 | 1 | 2 | 23 |
| E. coli | MPN/100 mL | NA | 1 | Weekly | <1 | <1 | 25 | <1 | <1 | 23 | <1 | <1 | 23 |
| Cryptosporidium | oocysts/L | Treatment Technique, MCLG = 0 | 0.089 | Quarterly | | <0.089 | 1 | | | | | | |
| Giardia lamblia | oocysts/L | Treatment Technique, MCLG = 0 | 0.089 | Quarterly | | <0.089 | 1 | | | | | | |
| Legionella | MPN/100 mL | Treatment Technique, MCLG = 0 | 10 | Quarterly | | <10 | 1 | | | | | | |
| Disinfection Byproducts | | | | | | | | | | | | | |
| Bromate | µg/L | 10 | 0.15 | Monthly | | 4.01 | 1 | | 4.19 | 1 | | 3.76 | 1 |
| Chlorite | mg/L | 1.0 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Trihalomethanes | | | | | | | | | | | | | |
| Bromodichloromethane | µg/L | | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Bromoform | µg/L | | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Chloroform | µg/L | | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Dibromochloromethane | µg/L | | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Total Trihalomethanes | µg/L | 80 | | | | | | | | | | | |
| HAAs | | | | | | | | | | | | | |
| Dichloroacetic acid | µg/L | | 0.60 | Monthly | | 1.27 | 1 | | 1.70 | 1 | | 1.75 | 1 |
| Trichloroacetic acid | µg/L | | 0.20 | Monthly | | 0.42 | 1 | | <0.2 | 1 | | 0.61 | 1 |
| Monochloroacetic acid | µg/L | | 0.60 | Monthly | | <0.6 | 1 | | <0.6 | 1 | | <0.6 | 1 |
| Bromoacetic acid | µg/L | | 0.40 | Monthly | | <0.4 | 1 | | <0.4 | 1 | | <0.4 | 1 |
| Dibromoacetic acid | µg/L | | 0.20 | Monthly | | 1.67 | 1 | | 0.34 | 1 | | 0.29 | 1 |
| Total Haloacetic Acids | µg/L | 60 | | | | | | | | | | | |

Appendix
Monitoring Data for SWIFT Water Quality Regulatory Targets

| Parameter | Units | Maximum Contaminant Level (MCL) or MCL Goal (MCLG) where numerical MCL not expressed. Values noted for indicator compounds are non-regulatory screening values | Minimum Report Level ¹ | Required Monitoring Frequency | October | | | November | | | December | | |
|---|-------|--|-----------------------------------|-------------------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|
| | | | | | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples |
| Disinfectants | | | | | | | | | | | | | |
| Monochloramine (as Cl ₂) ⁶ | mg/L | 4 | | Continuous | 0.59 | 1.33 | | 0.41 | 1.07 | | 0.30 | 0.55 | |
| Chlorine (as Cl ₂) ⁶ | mg/L | 4 | | Continuous | 0.60 | 1.19 | | 0.40 | 0.56 | | 0.30 | 0.53 | |
| Inorganic Chemical | | | | | | | | | | | | | |
| Antimony | µg/L | 6 | 0.5 | Monthly | | <0.5 | 1 | | <0.5 | 1 | | 0.6 | 1 |
| Arsenic | µg/L | 10 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Asbestos | MFL | 7 | 0.18 | Monthly | | <0.18 | 1 | | <0.18 | 1 | | <0.18 | 1 |
| Barium | mg/L | 2 | 0.005 | Monthly | | 0.013 | 1 | | 0.008 | 1 | | 0.007 | 1 |
| Beryllium | µg/L | 4 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Cadmium | µg/L | 5 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Chromium (total) | µg/L | 100 | 5 | Monthly | | <5 | 1 | | <5 | 1 | | <5 | 1 |
| Copper | mg/L | 1.3 (action level) | 0.005 | Monthly | | <0.005 | 1 | | <0.005 | 1 | | <0.005 | 1 |
| Cyanide (total) | µg/L | 200 | 10 | Monthly | | <10 | 1 | | <10 | 1 | | 23 | 1 |
| Fluoride | mg/L | 4.0 | 0.05 | Monthly | 1.05 | 1.94 | 25 | 0.95 | 1.04 | 22 | 0.88 | 0.94 | 24 |
| Lead | µg/L | 15 (action level) | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Mercury | µg/L | 2 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Selenium | µg/L | 50 | 5 | Monthly | | <5 | 1 | | <5 | 1 | | <5 | 1 |
| Thallium | µg/L | 2 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Organic Chemicals | | | | | | | | | | | | | |
| Acrylamide | µg/L | Treatment Technique, MCLG = 0 | 0.1 | Monthly | | <0.10 | 1 | | <0.10 | 1 | | <0.10 | 1 |
| Alachlor | µg/L | 2 | 0.05 | Monthly | | <0.05 | 1 | | <0.05 | 1 | | <0.05 | 1 |
| Atrazine | µg/L | 3 | 0.05 | Monthly | | <0.05 | 1 | | <0.05 | 1 | | <0.05 | 1 |
| Benzo(a)pyrene (PAHs) | µg/L | 0.2 | 0.02 | Monthly | | <0.02 | 1 | | <0.02 | 1 | | <0.02 | 1 |
| Di(2-ethylhexyl) adipate | µg/L | 400 | 0.6 | Monthly | | <0.6 | 1 | | <0.6 | 1 | | <0.6 | 1 |
| Di(2-ethylhexyl) phthalate | µg/L | 6 | 0.6 | Monthly | | <0.6 | 1 | | <0.6 | 1 | | <0.6 | 1 |
| Hexachlorocyclopentadiene | µg/L | 50 | 0.05 | Monthly | | <0.05 | 1 | | <0.05 | 1 | | <0.05 | 1 |
| Hexachlorobenzene | µg/L | 1 | 0.05 | Monthly | | <0.05 | 1 | | <0.05 | 1 | | <0.05 | 1 |
| Simazine | µg/L | 4 | 0.05 | Monthly | | <0.05 | 1 | | <0.05 | 1 | | <0.05 | 1 |
| Carbofuran | µg/L | 40 | 0.5 | Monthly | | <0.5 | 1 | | <0.5 | 1 | | <0.5 | 1 |
| Oxamyl (Vydate) | µg/L | 200 | 0.5 | Monthly | | <0.5 | 1 | | <0.5 | 1 | | <0.5 | 1 |
| Chlordane | µg/L | 2 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Endrin | µg/L | 2 | 0.01 | Monthly | | <0.01 | 1 | | <0.01 | 1 | | <0.01 | 1 |
| Heptachlor | µg/L | 0.4 | 0.01 | Monthly | | <0.01 | 1 | | <0.01 | 1 | | <0.01 | 1 |
| Heptachlor Epoxide | µg/L | 0.2 | 0.01 | Monthly | | <0.01 | 1 | | <0.01 | 1 | | <0.01 | 1 |
| Lindane | µg/L | 0.2 | 0.01 | Monthly | | <0.01 | 1 | | <0.01 | 1 | | <0.01 | 1 |
| Methoxychlor | µg/L | 40 | 0.05 | Monthly | | <0.05 | 1 | | <0.05 | 1 | | <0.05 | 1 |
| Toxaphene | µg/L | 3 | 0.5 | Monthly | | <0.5 | 1 | | <0.5 | 1 | | <0.5 | 1 |

Appendix
Monitoring Data for SWIFT Water Quality Regulatory Targets

| Parameter | Units | Maximum Contaminant Level (MCL) or MCL Goal (MCLG) where numerical MCL not expressed. Values noted for indicator compounds are non-regulatory screening values | Minimum Report Level ¹ | Required Monitoring Frequency | October | | | November | | | December | | |
|--|-------|--|-----------------------------------|-------------------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|
| | | | | | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples |
| PCB Arochlor1016 | µg/L | | 0.08 | Monthly | | <0.08 | 1 | | <0.08 | 1 | | <0.08 | 1 |
| PCB Arochlor1221 | µg/L | | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| PCB Arochlor1232 | µg/L | | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| PCB Arochlor1242 | µg/L | | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| PCB Arochlor1248 | µg/L | | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| PCB Arochlor1254 | µg/L | | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| PCB Arochlor1260 | µg/L | | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Total Polychlorinated Biphenyls (PCBs) | µg/L | 0.5 | | | | | | | | | | | |
| 2,4-D | µg/L | 70 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Dalapon | µg/L | 200 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Picloram | µg/L | 500 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| 2,4,5-TP (Silvex) | µg/L | 50 | 0.2 | Monthly | | <0.2 | 1 | | <0.2 | 1 | | <0.2 | 1 |
| Dinoseb | µg/L | 7 | 0.2 | Monthly | | <0.2 | 1 | | <0.2 | 1 | | <0.2 | 1 |
| Pentachlorophenol | µg/L | 1 | 0.04 | Monthly | | <0.04 | 1 | | <0.04 | 1 | | <0.04 | 1 |
| Dioxin (2,3,7,8-TCDD) | pg/L | 30 | 5 | Monthly | | <5 | 1 | | <5 | 1 | | <5 | 1 |
| Diquat | µg/L | 20 | 0.4 | Monthly | | <0.4 | 1 | | <0.4 | 1 | | <0.4 | 1 |
| Endothall | µg/L | 100 | 5 | Monthly | | <5 | 1 | | <5 | 1 | | <5 | 1 |
| Epichlorohydrin | µg/L | Treatment Technique, MCLG = 0 | 0.4 | Monthly | | <0.4 | 1 | | <0.4 | 1 | | <0.4 | 1 |
| Glycophosphate | µg/L | 700 | 6 | Monthly | | <6 | 1 | | <6 | 1 | | <6 | 1 |
| Benzene | µg/L | 5 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Carbon Tetrachloride | µg/L | 5 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Chlorobenzene | µg/L | 100 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| 1,2-dibromo-3-chloropropane (DBCP) | µg/L | 0.2 | 0.02 | Monthly | | <0.02 | 1 | | <0.02 | 1 | | <0.02 | 1 |
| o-Dichlorobenzene | µg/L | 600 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| p-Dichlorobenzene | µg/L | 75 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| 1,2-Dichloroethane | µg/L | 5 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| 1,1-Dichloroethylene | µg/L | 7 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| cis-1,2-Dichloroethylene | µg/L | 70 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| trans-1,2-Dichloroethylene | µg/L | 100 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Dichloromethane | µg/L | 5 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| 1,2-Dichloropropane | µg/L | 5 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Ethylbenzene | µg/L | 700 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Ethylene Dibromide (EDB) | µg/L | 0.05 | 0.02 | Monthly | | <0.02 | 1 | | <0.02 | 1 | | <0.02 | 1 |

Appendix
Monitoring Data for SWIFT Water Quality Regulatory Targets

| Parameter | Units | Maximum Contaminant Level (MCL) or MCL Goal (MCLG) where numerical MCL not expressed. Values noted for indicator compounds are non-regulatory screening values | Minimum Report Level ¹ | Required Monitoring Frequency | October | | | November | | | December | | |
|--|-------|--|-----------------------------------|-------------------------------|----------------------|-------------|-------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|
| | | | | | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples |
| Styrene | µg/L | 100 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Tetrachloroethylene | µg/L | 5 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Toluene | µg/L | 1,000 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| 1,2,4-Trichlorobenzene | µg/L | 70 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| 1,1,1-Trichloroethane | µg/L | 200 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| 1,1,2-Trichloroethane | µg/L | 5 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Trichloroethylene | µg/L | 5 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Vinyl Chloride | µg/L | 2 | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Total Xylene | µg/L | 10,000 | 3 | Monthly | | <3 | 1 | | <3 | 1 | | <3 | 1 |
| Radionuclides | | | | | | | | | | | | | |
| Alpha particles | pCi/L | 15 | 3 | Monthly | | <3 | 1 | | <3 | 1 | | <3 | 1 |
| Beta particles and photon emitters | pCi/L | 4 mrem/yr ⁷ | 3 | Monthly | | 18 | 1 | | 18 | 1 | | 18 | 1 |
| Radium 226 | pCi/L | 5 (226+228) | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Radium 228 | pCi/L | 5 (226+228) | 1 | Monthly | | <1 | 1 | | <1 | 1 | | <1 | 1 |
| Uranium | µg/L | 30 | 0.1 | Monthly | | <0.1 | 1 | | <0.1 | 1 | | <0.1 | 1 |
| Strontium-90 | pCi/L | NA | 0.676* | Monthly | | <0.676 | 1 | | <0.676 | 1 | | <0.676 | 1 |
| Tritium | pCi/L | NA | 390* | Monthly | | <390 | 1 | | <390 | 1 | | <390 | 1 |
| Non-regulatory Performance Indicators | | | | | | | | | | | | | |
| Public Health Indicators | | Trigger Limits | | | | | | | | | | | |
| 1,4-dioxane | µg/L | 1 | 0.06 | Quarterly | 0.55 | 0.58 | 2 | 0.52 | 0.56 | 4 | 0.54 | 0.62 | 4 |
| 17-β-estradiol | ng/L | TBD | 0.0044 | Quarterly | | <0.0044, D1 | 1 | | | | | | |
| DEET | ng/L | 200,000 | 10 | Quarterly | | <10 | 1 | | | | | | |
| Ethinyl estradiol | ng/L | TBD | 10 | Quarterly | | <10 | 1 | | | | | | |
| Tris(2-carboxyethyl)phosphine (TCEP) | ng/L | 5,000 | 10 | Quarterly | | <10 | 1 | | | | | | |
| NDMA | ng/L | 10 | 2 | Quarterly | <2 | <2 | 2 | <2 | <2 | 4 | <2 | <2 | 4 |
| Perchlorate | µg/L | 6 | 0.50 | Quarterly | | 0.70 | 1 | | | | | | |
| Perfluorooctanoic Acid (PFOA) | µg/L | 0.070 (PFOA+PFOS) | 0.002 | Quarterly | | <0.002 | 1 | | | | | | |
| Perfluorooctanesulfonic Acid (PFOS) | µg/L | 0.070 (PFOA+PFOS) | 0.002 | Quarterly | | <0.002 | 1 | | | | | | |
| Treatment Efficacy Indicators | | Trigger Limits | | | | | | | | | | | |
| Cotinine | ng/L | 1,000 | 10 | Quarterly | | <10, M1 | 1 | | | | | | |
| Primidone | ng/L | 10,000 | 5 | Quarterly | | <5 | 1 | | | | | | |
| Phenytoin (Dilantin) | ng/L | 2,000 | 20 | Quarterly | | <20 | 1 | | | | | | |
| Meprobamate | ng/L | 200,000 | 5 | Quarterly | | <5, M1 | 1 | | | | | | |
| Atenolol | ng/L | 4,000 | 5 | Quarterly | | <5 | 1 | | | | | | |
| Carbamazepine | ng/L | 10,000 | 5 | Quarterly | | <5 | 1 | | | | | | |
| Estrone | ng/L | 320 | 10 | Quarterly | | <10 | 1 | | | | | | |

Appendix
Monitoring Data for SWIFT Water Quality Regulatory Targets

| Parameter | Units | Maximum Contaminant Level (MCL) or MCL Goal (MCLG) where numerical MCL not expressed. Values noted for indicator compounds are non-regulatory screening values | Minimum Report Level ¹ | Required Monitoring Frequency | October | | | November | | | December | | |
|---|--------------------|--|-----------------------------------|-------------------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|----------------------|---------|-------------------|
| | | | | | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples | Average ² | Maximum | Number of Samples |
| Sucralose | ng/L | 150,000,000 | 100 | Quarterly | | 780 | 1 | | | | | | |
| Triclosan | ng/L | 210,000 | 20 | Quarterly | | <20 | 1 | | | | | | |
| Additional Monitoring (Ozone & UV LRV) | | | | | | | | | | | | | |
| Ozone Virus LRV | | | | Continuous | 4.50 | 3.36 | | 4.57 | 3.61 | | 4.51 | 3.94 | |
| Ozone Giardia LRV | | | | Continuous | 2.13 | 1.57 | | 2.31 | 1.83 | | 2.27 | 1.98 | |
| UV Dose Reactor 1 | mJ/cm ² | | | Continuous | >186 | >186 | | >186 | >186 | | >186 | >186 | |
| UV Virus LRV Reactor 1 | | | | Continuous | >4 | >4 | | >4 | >4 | | >4 | >4 | |
| UV Dose Reactor 2 | mJ/cm ² | | | Continuous | >186 | >186 | | >186 | >186 | | >186 | >186 | |
| UV Virus LRV Reactor 2 | | | | Continuous | >4 | >4 | | >4 | >4 | | >4 | >4 | |

¹ When minimum reporting limits varied during the quarter, the highest minimum reporting limit used is identified.

² Analytical results less than the reporting limit were treated as zero for the purposes of the averaging calculation.

³ Daily samples are typically not collected on days in which there is no or limited recharge. TOC sample collection occurs routinely on Monday, Wednesday and Friday when recharging. Limited or inconsistent recharge impacts the collection of daily samples, particularly for the microbiological samples collected for total coliform and e coli which have limited holding time requirements. Recharge occurred on 26 days in October, 25 days in November, and 29 days in December. Recharge was limited for an additional 1 day in October, 2 days in November and 6 days in December.

⁴ TDS of the Potomac Aquifer System is based on the averages within the upper, middle and lower Potomac Aquifer as determined during baseline monitoring.

⁵ A positive Total coliform result was documented on December 5 with a result of 1 CFU/100 mL and again on December 31 with a result of 2 CFU/100 mL. In both samples E. coli were absent.

⁶ The maximum residual disinfectant level (or MRDL) MCL for monochloramine and chlorine are based on annual averages.

⁷ The measurement unit for beta particles and photon emitters is pCi/L while the MCL is expressed as mrem/yr. Per EPA's Implementation Guidance for Radionuclides (EPA 816-F-00-002, March 2002), the screening threshold for beta particles and photon emitters is 50 pCi/L. If sample concentrations exceed 50 pCi/L, each individual beta particle and photon emitter is converted from pCi/L to mrem using the EPA designated conversion tables, currently available in the referenced document.

Contract Laboratory Flags

(D1) - Sample required dilution due to matrix.

(M1) - Matrix spike recovery was high; the associated blank spike recovery was acceptable.